



Major Geothermal  
 6285 West 48<sup>th</sup> Avenue, Wheat Ridge, Colorado 80033  
 303 / 424-1622 voice, 303 / 423-6795 fax  
 Toll free - 800 / 707-9479  
 www.majorgeothermal.com



**Single hydronic unit, single load tank, 2 to 6 tons, 8 to 12 tons.** Conceptual sketch, not scaled. May not show all valves, controls, charge and fill ports, specific piping sizes, or miscellaneous parts. Unit should be spec'd with a CuNi load coil to tolerate periodic maintenance for flushing of mineralization buildup if used for domestic heating and water supply has high TDS. **Note: The loadside circulator (A) is not intended to service the flow and pressure drop load of the fan coils, radiant infloor tubing, or their associated piping, valves or fittings.** You must still use dedicated, balanced circulator(s) for your infloor piping or fan coils, along with the appropriate manifolding and valving.

